

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated : 27.06.25

It is certified that an inspection team headed by Assistant Engineer (Name of Officer with Designation) From Uttarakhand Jal Sansthan (U.S. Nagar) (Name of Department/ Office) inspected the Phoenix Public School (Name & Address of the School) on 18.06.25 (Date of Inspection) and on the basis of Water test Report (Attached) bearing No. SI/UTS/DLWDQM/25-26 dated 18.06.25 of U.T.S. Lab U.S. Nagar (PHED Lab) certified that the Phoenix Public School (Name of the School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 Year.

Technical Manager
District Water Quality Testing
Monitoring Laboratory

Signature with Seal : Uttarakhand Jal Sansthan, U.S. Nagar
Name : Mukesh Kumar
Designation : Assistant Engineer
Name & Address of the office / Department:

Uttarakhand Jal Sansthan
U.S. Nagar.

To,

Phoenix Public School
Near Police Chowki
Daraw road Kichha, U.S. Nagar

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Rudrapur U.S.Nagar

E-mail: ceudmujs@gmail.com

Test Report ID: 51/UJS/DLWQTML/2025-26

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	Phoenix Public School Near Police Chowki Darau Road Kichha U.S.Nagar Uttarakhand		
Type of Source (Surface Water/ Ground Water/ Sub-Surface Water)	Sample Description:Ground Water		One water Sample Submitted From R O Purifier.
Reference Sample Identification:	DLWQTML/UJS/PPS-01		Date of Start of Analysis:18.06.2025
			Date of End of Analysis :20.06.2025
Date of Sample Received: 18.06.2025		Sample Collected by:	Customer

S.No.	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS)
1	Colour	Less than 5	5	15
2	Total Dissolved Solids (TDS), mg/l max	102	500	2000
3	pH at 25°C	7.26	6.5 to 8.5	No Relaxation
4	Turbidity, NTU max	0.46	1	5
5	Chloride, Mg/l max	2.99	250	1000
6	Total Alkalinity as CaCO ₃ mg/l max	78	200	600
7	Total Hardness as CaCO ₃ mg/l max	83	200	600
8	Calcium as Ca mg/l max	20	75	200
9	Magnesium as Mg mg/l max	8.01	30	100
Microbiological Test Parameters				
10	E.Coli MPN /100ml	Absent	Absent	Absent
11	Total Coliform/100ml	Absent	Absent	Absent

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

Chemist

Technical Manager
District Water Quality Testing
Quality/Technical Manager
Uttarakhand Jal Sansthan, U.S.Nagar

-End of Report-